

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7515-0531:001 Page 1 of 1

**CATEGORY:** Pipe/Fittings

**LISTEE:** Victaulic, PO Box 31, Easton PA 10844-0031  
Contact: Mike John \*(610) 559-3300 \*Fax (610) 923-3095

**DESIGN:** Models HP70, 72, 75, 77, 90, 99, 741 and 750 grooved fittings; PLAINLOCK fittings; Model 920 mechanical tee; For grooved, plain or beveled pipe. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, size, working pressure and UL label.

**APPROVAL:** Listed as fittings for use in fire sprinkler systems.

**NOTE:** Formerly 7551-0531:001

\*Rev. 08-21-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**AUGUST 21, 2003**

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager